

**Remeha B.V.  
Kanaal Zuid 110  
Postbus 32, NL-7300 AA Apeldoorn**

**DECLARATION**  
hydraulic test

**with regard to appliance type(s)**

**Remeha Gas 210 ECO Pro  
Remeha Gas 310/610 ECO Pro**

**Max working pressure 6 bar**

**Remeha declares that,  
the boilers are subjected to 13 bar waterpressure , during 10 minutes  
without any leakage observed.**

Apeldoorn, june 2011.



W.F. Tjihuis  
Approval manager